

2016 Code Software Review 2700 Sqft / 2-Story / 20% Glazing / 4 BDRMS.	2016 Building Features	2016 Building Features	2016 Building Features	2016 Building Features
Run	2016 Code	2016 HPA Opt. A w/ R-8	2016 HPW w/ 2x6 @ 24" o.c.	2016 HPW w/ 2x4 @ 16" o.c.
File Number	0	1	2	3
Software	CBECC-Res 2016.2.1 (868)	CBECC-Res 2016.2.1 (868)	CBECC-Res 2016.2.1 (868)	CBECC-Res 2016.2.1 (868)
Code Compliance - Worst Case				
Percentage Improvement	1.3%	2.1%	1.6%	0.7%
Compliance Margin (KTDV)	1.20	1.86	1.42	0.67
Proposed Design (KTDV)	89.16	88.50	88.94	89.69
Standard Design (KTDV)	90.36	90.36	90.36	90.36
Photovoltaic Offset	N/A	N/A	N/A	N/A
Proposed Design (EDR)	52.2	51.9	52.1	52.4
Required PV System Size (kWdc)	N/A	N/A	N/A	N/A
Battery System Size (kWdc)	N/A	N/A	N/A	N/A
2019 Compliance Margin EDR w/ Efficiency	N/A	N/A	N/A	N/A
2019 Compliance Margin EDR w/ PV	N/A	N/A	N/A	N/A
Envelope: Opaque Surfaces				
Wall Insulation - 2x4 Exterior Walls	N/A	N/A	N/A	R-15+R8 \$ 6,410
Wall Insulation - 2x6 Exterior Walls	R-19+R5	R-19+R5	R-19+R5 @ 24" o.c. \$ (384)	N/A \$ (7,073)
Wall Insulation - 2x4 Interior Garage Walls	N/A	N/A	N/A	R-15 \$ 482
Wall Insulation - 2x6 Interior Garage Walls	R-19	R-19	R-19 @ 24" o.c. \$ (39)	N/A \$ (534)
Wall Insulation - Kneewall @ Garage	R-19	R-19	R-19 @ 24" o.c. \$ (6)	R-19
Insulated Entry Door(s)	N/A	N/A	N/A	N/A
Wall Insulation - 2x4 Exterior Garage Walls	N/A	N/A	N/A	R-0+R8 \$ 895
Wall Insulation - 2x6 Exterior Garage Walls	R-0+R5	R-0+R5	R-0+R5 @ 24" o.c. \$ (69)	N/A \$ (1,042)
Attic Insulation - Flat Portions	R-30	R-30	R-30	R-30
Floor Insulation - Above Garage	R-19	R-19	R-19 @ 24" o.c. \$ (29)	R-19
Insulation Installation - QII	Required	Required	Required	Required
Insulation Installation [Verification] - QII	Required	Required	Required	Required
Air Infiltration [Testing] - Blower Door	5.0 ACH	5.0 ACH	5.0 ACH	5.0 ACH
Roofing Material	Tile	Tile	Tile	Tile
Roofing Properties (Reflectance / Emittance)	0.10 / 0.85	0.10 / 0.85	0.10 / 0.85	0.10 / 0.85
Radiant Barrier	N/A	Required \$ 230	N/A	N/A
Above Roof Deck Insulation	N/A	R-8 \$ 1,398	N/A	N/A
Below Roof Deck Insulation	R-13	N/A \$ (723)	R-13	R-13
Ventilated Attic (Yes / No)	Yes	Yes	Yes	Yes
HPA HERS Inspection	N/A	N/A	N/A	N/A
Envelope: Glazing (U-Factor / SHGC)				
Horizontal Slider	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23
Single Hung	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23
Fixed	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23
Patio Door	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23	0.34 / 0.23
HVAC: Space Heating, Cooling Systems				
Space Heating Type	Furnace	Furnace	Furnace	Furnace
Space Heating Efficiency (AFUE)	0.80	0.80	0.80	0.80
Space Cooling Type	ACSplit	ACSplit	ACSplit	ACSplit
Space Cooling Efficiency (SEER / EER)	14 / 11.7	14 / 11.7	14 / 11.7	14 / 11.7
SEER [Verification]	N/A	N/A	N/A	N/A
EER [Verification]	N/A	N/A	N/A	N/A
Refrigerant Charge [Verification/Testing]	Required	Required	Required	Required
Fan Watt Draw [Testing]	0.58 W/cfm	0.58 W/cfm	0.58 W/cfm	0.58 W/cfm
Adequate Airflow [Testing]	350 cfm/ton	350 cfm/ton	350 cfm/ton	350 cfm/ton
Low Leakage Air Handler [Verification]	N/A	N/A	N/A	N/A
HVAC: Duct System				
Duct Insulation R-Value	R-8	R-8	R-8	R-8
Duct Location	Attic	Attic	Attic	Attic
Buried Ducts [Verification]	N/A	N/A	N/A	N/A
Low Leakage (Tight) Ducts [Testing]	Required @ 5%	Required @ 5%	Required @ 5%	Required @ 5%
HVAC: Mechanical Ventilation				
Minimum Whole-House Ventilation, Continuous	65 cfm	65 cfm	65 cfm	65 cfm
Ventilation System Type	Exhaust	Exhaust	Exhaust	Exhaust
Ventilation System Efficiency (cfm / W/cfm)	65 / 0.25	65 / 0.25	65 / 0.25	65 / 0.25
Whole House Fan	N/A	N/A	N/A	N/A
Water Heating				
Water Heater Type	Tankless	Tankless	Tankless	Tankless
Water Heater Efficiency (EF)	0.82	0.82	0.82	0.82
Fuel Source	Natural Gas	Natural Gas	Natural Gas	Natural Gas
External Blanket	N/A	N/A	N/A	N/A
Drain Hot Water Recovery	N/A	N/A	N/A	N/A
Distribution Type	Standard	Standard	Standard	Standard
Solar Water Heater (Solar Fraction)	N/A	N/A	N/A	N/A
Costs				
		\$ 905	\$ (527)	\$ (862)
Compliance Margin Difference				
Percentage change in Compliance from Base		0.8%	0.3%	-0.6%
KTDV change in Compliance from Base		0.66	0.22	-0.53